

Feather River Air Quality Management District

Updated: 7/6/2012

Statewide ATCM Compliance Dates:

Fuel	Tier	Application	Horsepower	Compliance Date	Alternative Compliance Date
Diesel	0	Other than Genset	100-174	December 31, 2010	
Diesel	0	All	175-750	December 31, 2010	
Diesel	0	Other than Genset	50-99	December 31, 2011	
Diesel	0	All	751+	December 31, 2014	
Diesel	1 or 2	All	175-751+	December 31, 2014	12 years after initial installation*
Diesel	0	Generator Sets	50-174	December 31, 2015	
Diesel	1 or 2	All	50-174	December 31, 2015	12 years after initial installation*
Diesel	All	Emergency Use*	50+	None	
Diesel	3 or 4	All	50+	None	

*As defined by the Statewide Stationary ATCM.

Extensions:

Fuel	Tier	Application	Horsepower	Compliance Date	Category
Diesel	0, 1, 2	All	All	+2 years	Electrification
Diesel	0	All	All	December 31, 2020	Low-Use
Diesel	0	All	All	December 31, 2020	Intermittent-Use
Diesel	1 or 2	All	All	December 31, 2025	Low-Use
Diesel	1 or 2	All	All	December 31, 2025	Intermittent-Use

*All extension requests must be submitted to the District in writing and approved by the District prior to operating. New stickers are not issued for extensions.

Electrification Requirements: Replace the diesel engine with an electric motor within 2 years.

Low-use Requirements: Operate <200 hours/year; hour meter; annual reporting.

Intermittent-use Requirements: 2,000 hours total of additional operation; apply prior to the Statewide Compliance Date; hour meter; annual reporting; located more than 0.5 miles from all residential areas, schools, and hospitals.

Sticker # Range
0001 - 0999
1000 - 1999
2000 - 2999
3000 - 3999
4000 - 4999
5000 - 5999
6000 - 9999